



CERTIFICATE

No. Z10 003772 0003 Rev. 04

Holder of Certificate: Epec Oy
Laakeriväylä 1
60100 Seinäjoki
FINLAND

Certification Mark:



Product: Safety systems
Programmable Logic Controller

Model(s): Epec Safety Control Unit Family

Parameters: Programmable Logic Controller with CODESYS SIL2 runtime

Systematic capability: SC2
Supply voltage: 12/24 V
Operating temperature: -40°C to +85°C

All certified components are listed in report ES107167C_A in the currently valid revision.

Tested according to: IEC 61508-1:2010 (up to SIL 2)
IEC 61508-2:2010 (up to SIL 2)
IEC 61508-3:2010 (up to SIL 2)
EN ISO 13849-1:2023 (up to Cat 3, PLd)

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the Testing, Certification, Validation and Verification Regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: ES107167C

Valid until: 2031-06-28

Date, 2026-07-01

(Peter Weiß)